

PRIMARY HEALTH CENTRE UDAYAMPEROOR

CERTIFICATE OF DRINKING WATER

It is verified that water in the well of St. Sebastian's Public School, Udayamperoor, which was found unfit for drinking in the report of Kerala Water Authority, Quality Control Division, Kochi, with report number KWA/QA/TC/25/JULY19, with the defect of low pH, has undergone remedial measures such as addition of lime with 40mg/L and is now **safe for drinking.**

Udayamperoor

Date : 3 - 2 - 2020




HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
UDAYAMPEROOR
Section/Area
UDAYAMPEROOR - 682 307



Principal
St. Sebastian's Public School
Nadakkavu - P. O.
Udayamperoor-682307




Manager
St. Sebastian's Public School
Nadakkavu-P.O
Udayamperoor - 682 307