



Telephone: 0484-2623576  
email:-qcsdlmaradu@gmail.com

## KERALA WATER AUTHORITY



QUALITY CONTROL SUB DISTRICT LAB, NETTOOR - 682040 (NABL ACCREDITED)

### WATER TEST REPORT

ULR NO: TC1038623000000246F

Report of Issue Date: 30.01.2023

Customer Name & Address  ST SEBASTIANS PUBLIC SCHOOL UDAYAMPEROOR ERNAKULAM- 682307	Date of Receipt of Payment	23.01.2023
	Date of Sample received	25.01.2023
	Sample given by	Customer
	Sample Code	NTR/246/01/23
	Sample Name	Water
	Sample Condition	Good
	Source of Sample	TAP
	Sample Quantity	2 Litre
	Test performing dates :	

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	(NTU)	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.0	0.39
2	pH at --- 25°C	-	IS 3025 (Part 11)-1983(Reaffirmed 2017)	6.5 to 8.5	7.24
3	Total Alkalinity	(mg/litre)	IS 3025 (Part 23)-1986(Reaffirmed 2019)	200	15.80
4	Total Dissolved Solids (TDS)	(mg/litre)	IS 3025 (Part 16)-1984(Reaffirmed 2017)	500	48.0
5	Total Hardness (as CaCO3)	(mg/litre)	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	26.00
6	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	9.89

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer.  
2) The samples retain for 15 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed By

Authorized By

Technical Manager RIJA JOSEPH

Quality Manager ANNA LIMA KM

KWA/QCSDL/NTR/F-21	Issue Date : 04.10.2021
Ref No: Nil	Rev. Date : Nil
Page 1 of 1	

End of Report

Principal  
St. Sebastian's Public School  
Nadakkavu - P.O.  
Udayamperoor-682307



QUALITY MANAGER  
QCSDL NETTOOR

Manager  
St. Sebastian's Public School  
Nadakkavu-P.O.  
Udayamperoor - 682 307



AnyScanner



Telephone:0484-2623576  
email:-qcSDLmaradu@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040**

**WATER TEST REPORT**

Report No: NTR/246/01/23

Report of Issue Date: 30.01.2023

Customer Name &Address	Date of Receipt of Payment	23.01.2023
ST SEBASTIANS PUBLIC SCHOOL UDAYAMPEROOR ERNAKULAM- 682307	Date of Sample received	25.01.2023
	Sample given by	Customer
	Sample Code	NTR/246/01/23
	Sample Name	Water
	Sample Condition	Good
	Source of Sample	TAP
	Sample Quantity	2 Litre
Test performing dates :		From: 27.01.2023 to 28.01.2023

SL.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Sulphate	(mg/litre)	IS 3025 (Part 24)-1984(Reaffirmed 2017)	200	2.81
2	Iron (as Fe)	(mg/litre)	APHA 23rd Edition 3500 -Fe-MethodB(Phenanthroline Method)	1	<0.1
3	Fluoride	(mg/litre)	IS 3025 (Part 60)-2008(Reaffirmed 2013)	1	<0.1
4	Nitrate (as NO3)	(mg/litre)	APHA 23rd Edition(UV Screening Method) 2017	45	2.75

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .  
2) The samples retain for 15 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed By

Authorized By

Technical Manager *RJA*  
RJA JOSEPH

Quality Manager *ANNAMMA KM*  
ANNAMMA KM

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.2021
Ref.No:Nil	Page 1 of 1

End of Report

**QUALITY MANAGER  
QCSDL NETTOOR**

*ANNAMMA KM*

**Manager  
St. Sebastian's Public School  
Nadakkavu-P.O.  
Udayamperoor - 682 307**

*RJA*  
**Principal  
St. Sebastian's Public School  
Nadakkavu - P.O.  
Udayamperoor-682307**



AnyScanner



Telephone:0484-2623576  
email:-qcsdlmaradu@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040**  
**WATER TEST-BACTERIOLOGY REPORT**

Report of Issue Date: 30.01.2023

<b>Customer Name &amp;Address</b>		<b>Date of Receipt of Payment</b>	23.01.2023
<b>ST SEBASTIANS PUBLIC SCHOOL UDAYAMPEROOR ERNAKULAM- 682307</b>		<b>Date of Sample received</b>	25.01.2023
		<b>Sample given by</b>	Customer
		<b>Sample Code</b>	NTR/246/01/23
		<b>Sample Name</b>	Water
		<b>Sample Condition</b>	Good
		<b>Source of Sample</b>	TAP
		<b>Sample Quantity</b>	250 ml
		<b>Test performing dates :</b>	
<b>Sl. No.</b>	<b>Source</b>	<b>Coliforms per 100ml of sample</b>	<b>E Coli n 100 ml of sample</b>
1	Water sample submitted by the customer	ABSENT	ABSENT

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed By

Authorized By

Technical Manager

Quality Manager

ANNAMMA KM

KWA/QCSDL/NTR/F-21		Issue Date : 04.10.2021	
Ref No:Nil	Rev,Date :Nil	Page 1of 1	

End of Report



**QUALITY MANAGER  
QCSDL NETTOOR**

Manager

St. Sebastian's Public School  
Nadakkavu-P.O.  
Udayamperoor - 682 307

Principal  
St. Sebastian's Public School  
Nadakkavu - P.O.  
Udayamperoor-682307



AnyScanner