



Telephone:0484-2926286
email:-qcsdmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB,NETTOOR -682040
WATER TEST- BACTERIOLOGY REPORT

Report No:NTR/896/06/25

Report Issue Date:19.06.2025

Customer Name &Address ST SEBASTIAN PUBLIC SCHOOL UDHYAMPEROOR	Date of Receipt of Payment	05.06.2025
	Date of Sample received	18.06.2025
	Sample given by	Customer
	Sample Code	NTR/896/06/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	TAP WATER FOR DRINKING PURPOSE
	Sample Quantity	250ML
	Test performing date :18.06.2025 TO 19.06.2025	

Sl.No	Characteristics	Unit	Acceptable Limit as per IS 10500-2012	Result
1	Total Coliform	CFU/100ml	Shall not be Detected/100ml	ABSENT
2	E-Coli	CFU/100ml	Shall not be Detected/100ml	ABSENT

Remarks:-

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Reviewed & Analysed By

Bacteriologist

End of Report

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:13	Rev.Date :11.09.2024	Page 1 of 1



Telephone:0484-2926286

email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
WATER TEST REPORT

Report No:NTR/896/06/25

Customer Name & Address	Date of Receipt of Payment	Report Issue Date:19.06.2025
ST SEBASTIAN PUBLIC SCHOOL UDHYAMPEROOR	Date of Sample received	05.06.2025
	Sample given by	18.06.2025
	Customer	
	Sample Code	NTR/896/06/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	TAP WATER FOR DRINKING PURPOSE
	Sample Quantity	2LTR
Test performing date :18.06.2025 TO 19.06.2025		

Sl.No	Characteristics	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Nitrate (as NO ₃)	IS3025(PART 34/SEC.1)-2023	45	3.87
2	Iron (as Fe)	IS 3025 (Part 53)-2024	1	0.13
3	Acidity (as CaCO ₃)	IS 3025 (Part 22)-1986(Reaffirmed 2019)	--	5.70
4	Electrical conductivity at 25° C	IS 3025 (Part 14)-2013(Reaffirmed 2019)	--	84.94
5	Fluoride (as F)	APHA23rdEdition 4500 - F D	1	BDL(DL=0.1)
6	Sulphate (as So ₄)	IS 3025 (Part 24/Sec 1)2022	200	2.61
7	Residual Chlorine (RC)	IS 3025 (Part 26)-2021	Minimum 0.2	NIL



Analysed and Reviewed Authorized By
 TECHNICAL MANAGER

QUALITY MANAGER
 QCSDL NETTOOR

End of Report

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:13	Rev,Date :11.09.2024	Page 1of 1



Telephone:0484-2926286
email:-qcsdlmaradu@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, NETTOOR -682040
(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

WATER TEST REPORT

Report No:NTR/896/06/25


Report Issue Date:19.06.2025

Customer Name & Address ST SEBASTIAN PUBLIC SCHOOL UDHYAMPEROOR	Date of Receipt of Payment	05.06.2025
	Date of Sample received	18.06.2025
	Sample given by	Customer
	Sample Code	NTR/896/06/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	TAP WATER FOR DRINKING PURPOSE
	Sample Quantity	2LTR
	Test performing date :18.06.2025 TO 19.06.2025	

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Colour	Hazen	IS 3025 (Part 4)-2021	5	< 5
2	Odour		IS 3025 (Part 5)-2018	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.57
4	pH @ 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.47
5	Total Dissolved Solids (TDS)@180° C	mg/L	IS 3025 (Part 16)-2023	500	56.00
6	Total Alkalinity	mg/L	IS 3025 (Part 23)-2023	200	25.74
7	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	15.31
8	Calcium (as Ca)	mg/L	IS 3025 (Part 40)-2024	75	9.61
9	Magnesium (as Mg)	mg/L	IS 3025 (Part 46)-2023	30	1.45
10	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	30.00

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit



Analysed and Reviewed & Authorized By
TECHNICAL MANAGER

QUALITY MANAGER
QCSDL NETTOOR

End of Report

KWA/QCSDL/NTR/F-21	Issue Date : 22.09.21	Issue no:01
Rev No:13	Rev,Date :11.09.2024	Page 1of 1